





INSTRUCTION

TENUO | Wandauslegerleuchte
wall bracket luminaire


Zentralbatterie/ central battery

IP40 220 - 240 V / 0/50-60 Hz 3 x 1,5mm²(2,5mm²)
 0,5mm² - 2,5mm² 3 x 1,5mm²(2,5mm²) + 2 x 1,5mm²(2,5mm²) nur bei .72/.82 only for .72/.82




Zentralbatterie/ central battery

	671938.004	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,88
	671938.004.71	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,93
	671938.004.72	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,96
	671938.004.81	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,92
	671938.004.82	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,94
	672039.004	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,88
	672039.004.71	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,93
	672039.004.72	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,96
	672039.004.81	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,92
	672039.004.82	L 400, B 100, H 200	LED Modul 5W	5,6W	30m	1,94




Unsere Sicherheitsleuchten sind entsprechend den aktuell gültigen Leuchtenbauvorschriften gekennzeichnet. Die Form der Kennzeichnung ist wie folgt, als Beispiel dargestellt.



Feld 1: Bauart, Feld 2: Betriebsart, Feld 3: Einrichtungen wie Selbsttest u.s.w.

Die von uns gelieferten Leuchten sind als Leuchten in Dauerschaltung gekennzeichnet. Wollen Sie die Leuchten in Bereitschaftschaltung betreiben, muß der Eintrag in Feld 2 geändert werden. Bitte kennzeichnen Sie dann 1-lampige Leuchten mit 0 anstatt der 1 und mehrlampige Leuchten mit 2 anstatt der 3.

Our safety luminaires are marked according to the currently valid construction standards. The type of marking can be seen in the following example.




Field 1: Type of construction, Field 2: Type of operation, Field 3: Additional features such as self test etc.

The default type of operation of our luminaires is maintained. If you change the type of operation to non-maintained you will have to change the entry in field 2 Please change the "1" to "0" for luminaires equipped with 1 lamp and "3" to "2" for luminaires equipped with more than one lamp.



EN 12464



RZB
Rudolf Zimmermann,
Bamberg GmbH
Rheinstraße 16
D-96052 Bamberg
Deutschland
Telefon +49 951/79 09-0
Telefax +49 951/79 09-198
www.rzb.de
info@rzb-leuchten.de

EN 12464

